



Attestation of Conformity

ISO/IEC, EN & TIA Screen Continuity Class D / Category 5e Two Connector Channel


Legrand
128 Avenue de Lattre de Tassigny
F-87045 Limoges Cedex, France

Attestation of Conformity No. 1181030

This type of Class D / Category 5e screen continuity two connector channel has been tested by 3P Third Party Testing and complies with the Class D requirements of edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 5e requirements of ANSI/TIA-568-C.2. The channel is only specified for screen continuity and screening performance has therefore not been verified. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration, and consisting of the following Legrand components:


| | | |
|------------------------|--|--|
| <i>Cables:</i> | <i>Horizontal Cable, Flexible cable, Qualification Status:</i> | <i>P/N 32753 From patch cords P/N 51640 / 41 / 42 / 43 Manufacturer verified</i> |
| <i>Conn. Hardware:</i> | <i>Patch Panel, Wall Outlet, Qualification Status:</i> | <i>P/N HD02 P/N SA02 Manufacturer Verified</i> |
| <i>Patch Cords:</i> | <i>1,0 m, 2,0 m, 3,0 m and 5,0 m Qualification Status:</i> | <i>P/N 51640 / 41 / 42 / 43 Manufacturer Verified</i> |

Hoersholm, 26th February 2018



Ole Lambertsen
Test Responsible

Hoersholm, 26th February 2018



Jens Rytter Petersen
General Manager