

This certificate applies only to the apparatus tested. The

esponsibility for conformity of any apparatus having the same designation with that

manufacturer or responsible

repared according to LOVAG

perating Principles of mutual

The responsible certification

body as member of LOVAG

Conformity with the above mentioned Standard(s)

**LOVAG Test Instructions** wherever applicable.

this Certificate or reproductions of this page

following the exclusive use of

Only integral reproduction of

accompanied by any page(s)

on which are stated the tests

performed and the assigned rated characteristics of the

apparatus Tested, are

piry of this certificate ACAE certification

Certificate.

permitted without written mission from the LOVAG tory responsible for this

issues a Certificate of

This certificate has been

(Low Voltage Agreement Group) Objectives and

tested rests with the

vendor

recognition.

ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 - 24123 - BERGAMO (Italy) Tel. +390354175244 fax. +390354534662 e-mail:acaecert@tin.it



## Certificate of Conformity

LOVAG-Certificate No. IT 12.013 Page 1 of 2

#### **Apparatus**

Four pole circuit breaker  $400V (U_e)$  -  $500V (U_i)$  -  $4kV (U_{imp})$ 80A-100A-125A ( $I_{th}$ ) - 50/60Hz -  $I_{cu}$  25 kA/  $I_{cs}$  19 kA at 400V with electromagnetic over current release: C

#### Designation

 $DX^{3}/25 \text{ kA (type C } 80 \div 125 \text{ A)}$ 

Manufacturer or responsible vendor BTicino S.p.A. – Legrand Group Via Messina, 38 -20154 Milano

Tested for: Legrand SNC, 128 Avenue du Marechal du Lattre de Tassigny Tested by: ACAE Laboratory IB01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60947-2 (2009-02) Edition 4.1 EN 60947-2:2006+A1:2009

Test sequence I – II – III Annex C - H Constructional requirements

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below.

Utilization category A Suitable for isolation

> U<sub>i</sub> 500V U<sub>e</sub> 400 V 50/60Hz U<sub>imp</sub> 4kV  $I_{cu}$  25 kA I<sub>cs</sub> 19 kA  $I_{su}$  6.5 kA  $I_{\rm IT}$  6.5 kA

Operating cycles - without current: 7000 - with current: 1000

Tripping limits according to the declared time/current characteristics

Signatory of EA, IAF and ILAC Mutual Recognition Agreements Responsible Certification Body: ACAE Mauro Marchi

Authorized signature

Date: 2012.04.04





ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE

ia Tito Livio, 5 – 24123 – BERGAMO (Italy) el. +390354175244 fax. +390354534662 e-mail:acaecert@tin.it



# **Certificate** of Conformity

LOVAG-Certificate No. IT 12.013 Page 2 of 2

### Constructional requirements

- Marking according to clause 5.2 of IEC 60947-2
- Materials resistant to abnormal heat and fire according to clause 8.2.1.1.1 of IEC 60947-1
- Mechanical properties of terminals according to clause 8.2.4 of IEC 60947-1
- Effectiveness of indication of the main contact position of equipment suitable for isolation according to clause 8.2.5 of IEC 60947-1

This document includes Test report No.: 10.199-1 Issue date: 2012-02-16



PRD N°070B

Signatory of EA, IAF and ILAC Mutual Recognition Agreements Responsible Certification Body: ACAE Mauro Marchi

Authorized signature

Date: 2012.04.04